## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## FIRE ENGINEERING - BUILDING WATERIALS LISTING PRO

## LISTING SERVICE

**LISTING No.** 3240-0028:158 Page 1 of 1

CATEGORY: Duct Smoke Dectector Housing/Base

LISTEE: Notifier, A Pittway Company, One Fire-Lite Place, Northford CT 06472-1653

Contact: Larry Flood (203) 484-1200

**DESIGN**: Models DHX-501 and DHX-502 duct detector housing. Unit consists of a housing, relay,

electrical components, sampling and exhaust tubes and Model CPX-551 (CSFM No. 7271-0028:149) or SDX-551 (CSFM No. 727-0028:148) smoke detector head. Refer to

listee's data sheet for detailed product description and operational considerations.

**INSTALLATION**: In accordance with listee's printed instructions, applicable codes and ordinances and in a

manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, air velocity rating and UL label.

**APPROVAL**: Listed as a duct detector base for use in HVAC systems having air velocities between \*500

to 4000 ft/min. The bases may use only detector Models CPX-551 (CSFM Listing No. 7271-

0028:149) or SDX-551 (CSFM Listing No. 7272-0028:148).

**XLF**: 3240-1209:155\*

\*Corrected 11-02-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: MAY 7, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager